

2015 Water Quality Report for CITY OF MUNISING – INDUSTRIAL PARK

This report covers the drinking water quality for the City of Munising **Industrial Park**, for the calendar year 2015. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Residents of Munising Industrial Park get their water from 2 wells located near the Alger Maximum Correctional Facility. Both artesian wells are 158 ft. deep and no chemicals are added due to the high quality of the water.

The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility is rated as moderately high for our wells.

If you have any questions about this report, contact Ron Kleiman at 387-2419.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in source water include:
 - **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
 - **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.

STATEMENT ABOUT LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Munising Industrial Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2015 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2015. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/L:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

| Regulated Contaminant | MCL | MCLG | Level Detected | Sampled | Violation Yes / No | Typical Source of Contaminant |
|----------------------------------|---------------------|------|------------------------------------|---------|--------------------|--|
| Fluoride (ppb) | 4 | 4 | ND | 2015 | No | Erosion of natural deposits. |
| Nitrite (ppm) | 10 | 10 | 0.5 | 2015 | No | |
| Radiological Contaminant | | | | | | |
| Alpha emitters (pCi/L) | 15 | 0 | 0 | 8/14 | No | Erosion of natural deposits |
| Ra226/Ra228 combined | 5 | 0 | 0 | 8/14 | No | Erosion of natural deposits |
| Unregulated Contaminants | | | | | | |
| Sodium (ppm) | | | 6 | 2015 | No | Erosion of natural deposits. |
| Contaminant Subject to AL | Action Level | | 90% of Samples ≤ This Level | | | |
| Lead (ppb) | 15 | | 1.7 | 2015 | No | Corrosion of household plumbing systems; Erosion of natural deposits |
| Copper (ppb) | 1300 | | 330 | 2015 | No | Corrosion of household plumbing systems; Erosion of natural deposits |

| | | | | | | |
|--|--|--|--|--|--|--|
| | | | | | | |
| | | | | | | |
| | | | | | | |

For more information about your water, please call the Munising Water and Wastewater Superintendent Ron Kleiman at (906) 387-2419. The City Commission meets at 7:00 p.m. on the third Monday of each month at the City Hall. Please feel free to come and participate.

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.