

2019 Water Quality Report for CITY OF MUNISING

This report covers the drinking water quality for the **City of Munising**, for the calendar year 2019. Included are details about where your water comes from, what it contains, and how it compares to Environmental Protection Agency (EPA) and state standards.

Residents of Munising get their water from 4 wells. Well #1 (168 ft. deep) and #2 (175 ft. deep) are near the lakeshore, close to the municipal dock. Wells #3 (300 ft. deep) and #4 (247 ft. deep) are wells located on Varnum St. near the Ice Arena. Fluoride is added (at each pump house) for dental health. No other chemicals are added due to high water quality.

The State performed an assessment of our source water in 2003 to determine the susceptibility or the relative potential of contamination. The susceptibility is very low for well #1 & #2 and moderate for #3 & #4.

If you have any questions about this report, contact Ron Kleiman at 387-2419.

- **Contaminants and their presence in water:** Drinking Water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the **EPA's Safe Drinking Water Hotline (800-426-4791)**.
- **Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).
- **Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up

substances resulting from the presence of animals or from human activity.

- Contaminants that may be present in source water include:
 - T **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
 - T **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
 - T **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
 - T **Radioactive contaminants**, which are naturally occurring or be the result of oil and gas production and mining activities.
 - T **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

STATEMENT ABOUT LEAD: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Munising is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2019 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1 – December 31, 2019. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All of the data is representative of the water quality, but some are more than one year old.

Terms and abbreviations used below:

- **Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- **Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- **N/A:** Not applicable **ND:** not detectable at testing limit **ppb:** parts per billion or micrograms per liter **ppm:** parts per million or milligrams per liter **pCi/l:** picocuries per liter (a measure of radioactivity).
- **Action Level:** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes / No	Typical Source of Contaminant
Inorganic Contaminants							
Nitrate (ppm)	10	10	0.34		2019	NO	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Metals							
Arsenic (ppm)	10	0	0.0024		2019	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.014		2019	No	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Beryllium (ppm)	0.004	0.004	0.0015		2019	No	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppm)	0.005	0.005	0.0012		2019	No	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Chromium (ppm)	0.1	0.1	0.0015		2019	No	Discharge from steel and pulp mills; erosion of natural deposits
Unregulated Contaminants							
Hardness, Total as CaCO ₃ (Mg/L)			86		2019	No	Erosion of natural deposits
Sodium (ppm)			1.1		2019	NO	Erosion of natural deposits.
Sulfate (ppm)			7.1		2019	NO	Erosion of natural deposits.
Inorganic Contaminant Subject to AL	AL	MCLG	Your Water 90 th Percentile Value	# of Samples Above AL	Year Sampled	Does System Exceed AL? Yes / No	Typical Source of Contaminant
Lead (ppb)	15	0	3.0	0	2018	NO	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.09	0	2018	NO	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives

For more information about your water, please call the Munising Water and Wastewater Superintendent Ron Kleiman at (906) 387-2419. The City Commission meets at 7:00 p.m. on the first Wednesday and third Monday of each month at the City Hall. Please feel free to come and participate. The Consumer Confidence Report can be found at www.cityofmunising.org, click on departments tab then water-sewer.

For more information about safe drinking water, visit the U.S. Environmental Protection Agency at www.epa.gov/safewater/.